

CHEMICAL RESISTANCE TESTING

Accidental Discharge of Strong Chemicals into Sewer Lines per NACE TM 0174-2022 Procedure B

TEST	PROTECTO 401™ Results 40 mil Nominal Thickness
1. Strong Acids	Pass - 50% Sulfuric, 30% Hydrochloric
2. Strong Base	Pass - 50% Sodium Hydroxide
3. Strong Solvents	Pass - Gasoline, 111 Trichlorethylene, Methyl Isobutyl Ketone, Propylene Glycol, Toluene, Hi-Sol 15
4. Strong Oxidizer	Pass - 50% Hydrogen Peroxide